

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

# **AR28**

# **Power Distribution Unit**

## Application and Operational Considerations

**Application:** Considered application of this Distribution Unit, is for connection from a 3ph 400V 125A max load supply, to downstream units requiring 63A 3phase connectivity to a maximun load of 125A combined from all output sockets, per phase. The outputs are balanced off each L1, L2 & L3 incoming phase.

**Note:** The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should **NOT** run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



#### **Unit Specification**

Unit Standard:	BS EN 61439-3			
Unit Guide Weight:				
Approx Dim: WxDxH	560x350x340			
Enclosure (IP):	IP44			
Impact (IK)	IK>06			
Unit Max. Amps:	125A			
Voltage (V):	400V			
Frequency Hz:	50Hz			
Short Circuit Rating:	6kA			
Continuous Load:	70%			

### **Supply Connection**

Inlet Standard:	BS EN 60309-1+2
Amperage (A):	125
Voltage:	400
Connection:	3ph+N+E Appliance inlet

#### Supply Isolation

Зр МСВ	125A

#### Load Connection

Outlets Standard:	BS EN 60309-1+2
3ph Voltage:	400

#### Connectivity

3ph+N+E
3ph+N+E

#### **Protection Devices**

Device	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
1x MCB	400	C125		6	BS EN 60898
3x RCBO	400	C32	30	10	BS EN 61009
3x RCCB	400	63A	10	3	BS EN 61008
3x MCB	400	C63	VIR	10	BS EN 60898