

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

AR 31

Power Distribution Unit

Application and Operational Considerations

Application: Considered application of this Distribution Unit, is for connection from a 3ph 400V 125A max load supply, to downstream units requiring 63A 230V single phase connectivity to a maximun load of 125A combined from all output sockets, per phase. The output sockets are balanced off each L1, L2 & L3 incoming phase.

Note: The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should **NOT** run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



Unit Specification

Unit Standard:	BS EN 61439-3
Unit Guide Weight:	
Approx Dim: WxDxH	570x350x340
Enclosure (IP):	IP44
Impact (IK)	IK>06
Unit Max. Amps:	125A
Voltage (V):	400V
Frequency Hz:	50Hz
Short Circuit Rating:	6kA
Continuous Load:	70%

Supply Connection

Inlet Standard:	BS EN 60309-1+2
Amperage (A):	125
Voltage:	400
Connection:	3ph+N+E Appliance inlet

Supply Isolation

4p MCB	125A

Load Connection

Outlets Standard:	BS EN 60309-1+2
1ph Voltage:	230

Connectivity

6x 63A	L+N+E

Protection Devices

Device	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
МСВ	400	D125		6	BS EN 60898
6x MCBs	230	C63	VIR	10	BS EN 60898
+ 6x Shunts with VELRs	230				