

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

AR40

Power Distribution Unit

Application and Operational Considerations

Application: Considered application of this Distribution Unit, is for connection from a 3ph 400V 125A max load supply, to downstream units requiring 63A 3phase connectivity to a maximun load of 125A combined from all output sockets, per phase. The outputs are balanced off each L1, L2 & L3 incoming phase.

Note: The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should NOT run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



Load Connection

Unit Specification

Unit Standard:	BS EN 61439-3
Unit Guide Weight:	
Approx Dim: WxDxH	400x350x340
Enclosure (IP):	IP44
Impact (IK)	IK>06
Unit Max. Amps:	125A
Voltage (V):	400V
Frequency Hz:	50Hz
Short Circuit Rating:	6kA
Continuous Load:	70%

Supply Connection

Inlet Standard:	BS EN 60309-1+2
Amperage (A):	125
Voltage:	400
Connection:	3ph+N+E Appliance inlet

Supply Isolation

Switch Standard:	BS EN 60947-2
Switch	125A

Outlets Standard:	BS EN 60309-1+2
3ph Voltage:	400

Connectivity

2x 63A Sockets	3ph+N+E		

Protection Devices

Device (s)	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
2x MCBs	400	C63	VIR	10	BS EN 60898
+ 2x Shunts with VELRs					

www.tempower.co.uk