

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

# **BR06**

## **Power Distribution Unit**

## Application and Operational Considerations

**Application:** Considered application of this Distribution Unit, is for connection from a 3ph 400V 63A max load supply, to downstream units requiring 32A single phase connectivity to a maximun load of 63A combined from all output sockets, per phase. The outputs are balanced off each L1, L2 & L3 incoming phase.

**Note:** The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should **NOT** run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



#### **Unit Specification**

Unit Standard:	BS EN 61439-3
Unit Guide Weight:	
Approx Dim: WxDxH	400x350x330
Enclosure (IP):	IP44
Impact (IK)	IK>06
Unit Max. Amps:	63A
Voltage (V):	240V
Frequency Hz:	50Hz
Short Circuit Rating:	6kA
Continuous Load:	70%

### **Supply Connection**

Inlet Standard:	BS EN 60309-1+2
Amperage (A):	63
Voltage:	240
Connection:	L+N+E Appliance inlet

#### Supply Isolation

4р МСВ	63A

#### Load Connection

Outlets Standard:	BS EN 60309-1+2
1ph Voltage:	230

#### Connectivity

12x 16a Sockets	L+N+E

#### **Protection Devices**

Device	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
12x RCBO	230	C16	30	6	BS EN 60898