

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

CR04

Power Distribution Unit

Application and Operational Considerations

Application: Considered application of this Distribution Unit, is for connection from a 3ph 400V 32A max load supply, to downstream units requiring 32A single phase connectivity to a maximun load of 32A combined per phase. The outputs are balanced off each L1, L2 & L3 incoming phase.

Note: The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should **NOT** run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



Unit Specification

Unit Standard:	BS EN 61439-3
Unit Guide Weight:	
Approx Dim: WxDxH	420x200x200
Enclosure (IP):	IP44
Impact (IK)	IK>06
Unit Max. Amps:	32A
Voltage (V):	240V
Frequency Hz:	50Hz
Short Circuit Rating:	6kA
Continuous Load:	70%

Supply Connection

Inlet Standard:	BS EN 60309-1+2
Amperage (A):	32
Voltage:	240
Connection:	L+N+E Appliance inlet

Supply Isolation

N/A

Load Connection

Outlets Standard:	BS EN 60309-1+2
1ph Voltage:	230

Connectivity

3x 32A Sockets	L+N+E

Protection Devices

Device	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
RCBO	230	C32	30	6	BS EN 60898

www.tempower.co.uk