

Tempower Ltd 4, Two Counties Estate, Haverhill, Suffolk CB9 7XZ Telephone: 0845 606 6049

# CR 2A

## **Power Distribution Unit**

## Application and Operational Considerations

**Application:** Considered application of this Distribution Unit, is for connection from a 3ph 400V 125A max load supply, to downstream units requiring 16A or 32A 230V single phase connectivity and 32A or 63A 3phase connectivity to a maximum load of 125A combined from all output sockets, per phase. The outputs are balanced off each L1, L2 & L3 incoming phase.

**Note:** The total load drawn per phase should be checked for optimum balance of all phases, with minimal differences, and not exceed the stated amperage of connectivity on any of the output panel sockets. Unit should **NOT** run on continuous full load for long periods of time on any of the connections. Unit shall be installed and used by a competent Electrician whom shall ensure that application design, installation and testing is compliant with BS7671.



### **Unit Specification**

Unit Standard:	BS EN 61439-3
Unit Guide Weight:	
Approx Dim: WxDxH	400x350x340
Enclosure (IP):	IP44
Impact (IK)	IK>06
Unit Max. Amps:	32A
Voltage (V):	400V
Frequency Hz:	50Hz
Short Circuit Rating:	
Continuous Load:	70%

## **Supply Connection**

Inlet Standard:	BS EN 60309-1+2		
Amperage (A):	32		
Voltage:	400		
Connection:	L+N+E Appliance inlet		

#### Supply Isolation

#### Load Connection

Outlets Standard:	BS EN 60309-1+2
1ph Voltage:	230

#### Connectivity

9x 16A Sockets	L+N+E

#### **Protection Devices**

Device	Voltage	Rating Type & Amperage	Character - mA	kA - Short Circuit Rating	Device Standard(s)
МСВ	400	C32		10	BS EN 60898
9x RCBO	230	C16	30	6	BS EN 61009

## www.tempower.co.uk